



TEST REPORT

Report No.: G8522.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Composite Window Assembly
incorporating a Casement/Fixed/Casement over Triple Awning

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Summary of Results		
Title	Test Specimen #1	Test Specimen #2
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class CW PG30 2902 x 2438 (114 x 96) Type C	Class LC PG45 2902 x 2438 (114 x 96) Type C
Design Pressure	±1440 Pa (30.08 psf)	±2160 Pa (45.11 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)	-----
Air Exfiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)	-----
Canadian Air Infiltration/Exfiltration Level	A3	-----
Water Penetration Resistance Test Pressure	220 Pa (4.60 psf)	330 Pa (6.90 psf)

Test Completion Date: 03/20/17

Reference must be made to Report No. G8522.01-901-44, dated 04/07/17 for complete test specimen description and detailed test results.