



TEST REPORT

Report No.: H0669.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Composite Window Assembly incorporating a Fixed over Fixed

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class CW PG30 2273 x 2425 (90 x 96) Type FW
Design Pressure	±1440 Pa (30.08 psf)
Air Infiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Air Exfiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	220 Pa (4.59 psf)

Test Completion Date: 05/23/17

Reference must be made to Report No. H0669.01-901-44, dated 06/27/17 for complete test specimen description and detailed test results.