



TEST REPORT

Report No.: F6486.01-901-44

Rendered to:
VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:
PVC Composite Window Assembly, incorporating a Fixed/Fixed over
Awning/Awning with and without Passive Air ventilator (PAV)
SERIES/MODEL: Endurance

SPECIFICATIONS:
AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and
AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and
CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class CW PG35 2440 x 2133 (96 x 84) Type AP
Design Pressure	±1680 Pa (35.09 psf)
Air Infiltration with PAV exposed and closed	0.02 L/s/m ² (<0.01 cfm/ft ²)
Air Infiltration without PAV	0.01 L/s/m ² (<0.01 cfm/ft ²)
Air Exfiltration with PAV exposed and closed	0.04 L/s/m ² (<0.01 cfm/ft ²)
Air Exfiltration without PAV	0.03 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level with PAV exposed and closed	A3
Canadian Air Infiltration/Exfiltration Level without PAV	A3
Water Penetration Resistance Test Pressure with PAV exposed and closed	260 Pa (5.43 psf)
Water Penetration Resistance Test Pressure without PAV	260 Pa (5.43 psf)

Test Completion Date: 03/23/16

Reference must be made to Report No. F6486.01-901-44, dated 04/01/16 for complete test specimen description and detailed test results.