



TEST REPORT

Report No.: F6385.01-901-44

Rendered to:
VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:
PVC Composite Window Assembly, incorporating a Fixed/Fixed over
Awning/Awning over Fixed/ Fixed
SERIES/MODEL: Endurance

SPECIFICATIONS:
AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and
AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*
and
CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG30 2132 x 2946 (84 x 116) Type AP
Design Pressure	±1440 Pa (30.08 psf)
Air Infiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Air Exfiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	220 Pa (4.60 psf)

Test Completion Date: 03/23/16

Reference must be made to Report No. F6385.01-901-44, dated 03/29/16 for complete test specimen description and detailed test results.