



TEST REPORT

Report No.: F8392.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Horizontal Sliding Window (XO) with Passive Air Ventilator (PAV)

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11 Design Pressure	Class LC PG40 2440 x 1600 (96 x 63) Type HS ±1920 Pa (40.10 psf)
Air Infiltration with PAV closed and exposed	0.78 L/s/m ² (0.15 cfm/ft ²)
Air Infiltration without PAV	0.32 L/s/m ² (0.06 cfm/ft ²)
Air Exfiltration with PAV closed and exposed	0.72 L/s/m ² (0.14 cfm/ft ²)
Air Exfiltration without PAV	0.41 L/s/m ² (0.08 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level with PAV closed and exposed	A2
Canadian Air Infiltration/Exfiltration Level without PAV	A3
Water Penetration Resistance Test Pressure with PAV closed and exposed	440 Pa (9.20 psf)
Water Penetration Resistance Test Pressure without PAV	440 Pa (9.20 psf)

Test Completion Date: 05/23/16

Reference must be made to Report No. F8392.01-901-44, dated 05/26/16 for complete test specimen description and detailed test results.