



TEST REPORT

Report No.: G8524.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Composite Window Assembly
incorporating Twin Fixed Lites over Twin Fixed Lites

SERIES/MODEL: Endurance

SPECIFICATIONS:

*AAMA/WDMA/CSA 101/I.S.2/A440-11, NAFS 2011 - North American Fenestration
Standard/Specification for Windows, Doors, and Skylights*

and

*AAMA/WDMA/CSA 101/I.S.2/A440-08, NAFS - North American Fenestration
Standard/Specification for Windows, Doors, and Skylights*

and

*CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, NAFS - North
American Fenestration Standard/Specification for Windows, Doors, and Skylights*

| Title | Summary of Results |
|----------------------------------------------|-------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11 | Class LC PG35 2438 x 2643 (96 x 104) Type F |
| Design Pressure | ±1680 Pa (35.09 psf) |
| Air Infiltration | <0.05 L/s/m ² (<0.01 cfm/ft ²) |
| Air Exfiltration | <0.05 L/s/m ² (<0.01 cfm/ft ²) |
| Canadian Air Infiltration/Exfiltration Level | A3 |
| Water Penetration Resistance Test Pressure | 260 Pa (5.43 psf) |

Test Completion Date: 03/14/17

Reference must be made to Report No. G8524.01-901-44, dated 04/06/17 for complete test specimen description and detailed test results.