



TEST REPORT

Report No.: F9685.01-901-44

Rendered to:

VPI QUALITY WINDOWS Spokane, Washington

PRODUCT TYPE: Single Hung Window with Passive Air Ventilator (PAV) **SERIES/MODEL**: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights

AAMA/WDMA/CSA 101/I.S.2/A440-08, NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG55 1220 x 2134 (48 x 84) Type H
Design Pressure	±2640 Pa (55.14 psf)
Air Infiltration	0.78 L/s/m² (0.15 cfm/ft²)
(with passive air ventilator exposed and closed)	
Air Infiltration	0.46 L/s/m² (0.09 cfm/ft²)
(without passive air ventilator)	
Air Exfiltration	0.84 L/s/m² (0.16 cfm/ft²)
(with passive air ventilator exposed and closed)	
Air Exfiltration	0.56 L/s/m² (0.11 cfm/ft²)
(without passive air ventilator)	
Canadian Air Infiltration/Exfiltration Level	A2
Water Penetration Resistance Test Pressure	470 Pa (9.20 psf)

Test Completion Date: 06/14/16

Reference must be made to Report No. F9685.01-901-44, dated 07/12/16 for complete test specimen description and detailed test results.