

**TEST REPORT**

**Report No.:** C6531.01-901-44

**Rendered to:**

VPI QUALITY WINDOWS  
Spokane, Washington

**PRODUCT TYPE:** PVC Composite Window Assembly  
incorporating Casement/Fixed Casement over  
Triple Fixed with an integral ventilator

**SERIES/MODEL:** Endurance

**SPECIFICATION:** AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

<b>Title</b>	<b>Summary of Results</b>
Primary Product Designator	Class CW - PG40 2744 x 2133 (108 x 84) Type C
Primary Product Designator	Class LC - PG45 2744 x 2133 (108 x 84) Type C
Design Pressure	±1920 Pa (40.10 psf)
Design Pressure	±2160 Pa (45.11 psf)
Air Infiltration w/ventilator exposed and closed	0.83 L/s/m <sup>2</sup> (0.16 cfm/ft <sup>2</sup> )
Air Infiltration w/ventilator isolated from the test	0.55 L/s/m <sup>2</sup> (0.11 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	A2
Water Penetration Resistance Test Pressure	720 Pa (15.04 psf)

**Test Completion Date:** 03/06/2013

Reference must be made to Report No. C6531.01-901-44, dated 04/02/13, for complete test specimen description and detailed test results.