



**TEST REPORT**

**Report No.:** F2176.01-901-44

**Rendered to:**

VPI QUALITY WINDOWS  
Spokane, Washington

**PRODUCT TYPE:**

PVC Composite Window Assembly  
incorporating a Fixed/Fixed over Fixed/Fixed

**SERIES/MODEL:** Endurance

**SPECIFICATIONS:**

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

<b>Title</b>	<b>Summary of Results</b>
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG60 1855 x 1696 (73 x 67) Type FW
Design Pressure	±2880 Pa (60.15 psf)
Air Infiltration	<0.01 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Air Exfiltration	<0.01 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	720 Pa (15.04 psf)

**Test Completion Date:** 12/04/15

Reference must be made to Report No. F2176.01-901-44, dated 01/08/16 for complete test specimen description and detailed test results.