

TEST REPORT

Report No.: D5905.02-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

SERIES/MODEL: Endurance

PRODUCT TYPE: PVC Composite Window Assembly
incorporating two Casement Vents and seven Fixed Lites

SPECIFICATIONS:

*AAMA/WDMA/CSA 101/I.S.2/A440-08, NAFS - North American Fenestration
Standard/Specification for Windows, Doors, and Skylights*

*A440S1-09 - Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, NAFS North
American Fenestration Standard/Specification for Windows, Doors, and Skylights*

*AAMA/WDMA/CSA 101/I.S.2/A440-11, NAFS 2011 - North American Fenestration
Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
Primary Product Designator	Class LC PG45 2744 x 2437 (108 x 96) Type C
Design Pressure	±2160 Pa (45.11 psf)
Air Infiltration	0.24 L/s/m ² (0.05 cfm/ft ²)
Air Exfiltration	0.24 L/s/m ² (0.05 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	720 Pa (15.04 psf)

Test Completion Date: 03/26/2014

Reference must be made to Report No. D5905.02-901-44, dated 07/09/14, for complete test specimen description and detailed test results.