



TEST REPORT

Report No.: F4863.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Composite Window Assembly incorporating a Triple Fixed over Triple Fixed

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class CW PG35 2743 x 2438 (108 x 96) Type FW
Design Pressure	±1680 Pa (35.09 psf)
Air Infiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Air Exfiltration	<0.01 L/s/m ² (<0.01 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	720 Pa (15.04 psf)

Test Completion Date: 02/11/16

Reference must be made to Report No. F4863.01-901-44, dated 02/19/16 for complete test specimen description and detailed test results.