



Architectural Testing

TEST REPORT

Report No.: E1942.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE: PVC Horizontal Sliding Window (XOX)

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11 Design Pressure	Class LC PG30 2741 x 1675 (108 x 66) Type HS ±1440 Pa (30.08 psf)
Air Infiltration (with passive air ventilator exposed and closed)	0.89 L/s/m ² (0.18 cfm/ft ²)
Air Infiltration (without passive air ventilator)	0.78 L/s/m ² (0.15 cfm/ft ²)
Air Exfiltration (with passive air ventilator exposed and closed)	0.91 L/s/m ² (0.18 cfm/ft ²)
Air Exfiltration (without passive air ventilator)	0.83 L/s/m ² (0.16 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A2
Water Penetration Resistance Test Pressure	360 Pa (7.52 psf)

Test Completion Date: 10/27/14

Reference must be made to Report No. E1942.01-901-44, dated 11/25/14 for complete test specimen description and detailed test results. technique