

22155 68th Avenue South Kent, Washington 98032

Telephone: 253-395-5656 Facsimile: 717-764-4129 www.intertek.com/building

TEST REPORT FOR VPI QUALITY WINDOWS

Report No.: I2449.01-901-44 RO

Date: 09/25/18

REPORT ISSUED TO

VPI QUALITY WINDOWS

3420 E. Ferry Avenue Spokane, Washington 99202

SECTION 1

SCOPE

Intertek Building & Construction (B&C) was contracted by VPI Quality Windows to perform testing in accordance with the referenced Test Methods on their Endurance PVC Composite Assembly Twin Single Hung Window, H. Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek-ATI test facility in Kent, Washington. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.

SECTION 2

SUMMARY OF TEST RESULTS

TITLE	RESULTS
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG45 2235 x 2438 (88 x 96) Type H
Design Pressure	±2160 Pa (45.11 psf)
Air Infiltration	0.54 L/s/m² (0.11 cfm/ft²)
Air Exfiltration	0.45 L/s/m ² (0.09 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A2
Water Penetration Resistance Test Pressure	360 Pa (7.52 psf)

For INTERTEK B&C:

COMPLETED BY:	Che Rodriguez	REVIEWED BY:	Guillermo Silva
TITLE:	Technician	TITLE:	Laboratory Manager
SIGNATURE:	Che Rodogeorg	SIGNATURE:	Digitally Signed by: Guillermo Silva
DATE:	09/25/18	DATE:	09/25/18
GS:pac			

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Version: 07/24/17 Page 2 of 11 RT-R-AMER-Test-2804