



**TEST REPORT**

**Report No.:** G7930.01-901-44

**Rendered to:**

VPI QUALITY WINDOWS  
Spokane, Washington

**PRODUCT TYPE:**

PVC Horizontal Sliding Window (XOX)

**SERIES/MODEL:** Endurance 531

**SPECIFICATIONS:**

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, *Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

<b>Title</b>	<b>Summary of Results</b>
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG50 3050 x 1523 (120 x 60) Type HS
Design Pressure	±2400 Pa (50.13 psf)
Air Infiltration	0.30 L/s/m <sup>2</sup> (0.06 cfm/ft <sup>2</sup> )
Air Exfiltration	0.30 L/s/m <sup>2</sup> (0.06 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	360 Pa (7.52 psf)

**Test Completion Date:** 02/13/17

Reference must be made to Report No. G7930.01-901-44, dated 03/14/17 for complete test specimen description and detailed test results.