

## TEST REPORT FOR VPI QUALITY WINDOWS

Report No.: J3051.01-901-44 R0

Date: 03/12/19

### REPORT ISSUED TO

#### VPI QUALITY WINDOWS

3420 E. Ferry Avenue

Spokane, WA 99202

### SECTION 1

#### SCOPE

Intertek Building & Construction (B&C) was contracted by VPI Quality Windows, Spokane, Washington, to perform testing in accordance with the referenced Test Methods on their Endurance – PVC Composite Assembly with Single Hung Window over Single Fixed Lite – SH-A – 42" x 144". Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek-ATI test facility in Kent, Washington. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.

### SECTION 2

#### SUMMARY OF TEST RESULTS

TITLE	RESULTS
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class-CW PG45 Size Tested: 1067 x 3658 mm* (42 x 144 in*) Type SH
Design Pressure	±2160 Pa (45.11 psf)
Air Infiltration	<0.6 L/s/m <sup>2</sup> (0.12 cfm/ft <sup>2</sup> )*
Air Exfiltration	<0.1 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )*
Water Penetration Resistance Test Pressure	330 Pa (6.90 psf)*

Reference must be made to Intertek B&C Report No. J3051.01-901-44 R0, dated 03/12/19 for complete test specimen description and detailed test results.

\*Reference Intertek B&C Report No. J3052.01-901-44 R0, dated 03/12/19 for complete test specimen description and test results.

For INTERTEK B&C:

<b>COMPLETED BY:</b>	Che Rodriguez	<b>REVIEWED BY:</b>	Kenny White
<b>TITLE:</b>	Technician	<b>TITLE:</b>	Laboratory Manager
<b>SIGNATURE:</b>	 <small>Digitally Signed by: Che Rodriguez</small>	<b>SIGNATURE:</b>	 <small>Digitally Signed by: Kenny C. White</small>
<b>DATE:</b>	03/12/19	<b>DATE:</b>	03/12/19

EC:cns

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.