



TEST REPORT

Report No.: F3982.02-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE: PVC Fixed Window

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

| Title | Summary of Results |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11 | Class CW PG40 1830 x 2438 (72 x 96) Type FW |
| Design Pressure | ±1920 Pa (40.10 psf) |
| Air Infiltration | <0.01 L/s/m ² (<0.01 cfm/ft ²) |
| Air Exfiltration | <0.01 L/s/m ² (<0.01 cfm/ft ²) |
| Canadian Air Infiltration/Exfiltration Level | Fixed |
| Water Penetration Resistance Test Pressure | 720 Pa (15.04 psf) |

Test Completion Date: 01/08/16

Reference must be made to Report No. F3982.02-901-44, dated 02/23/16 for complete test specimen description and detailed test results.