

TEST REPORT**Report No.:** G9229.01-901-44**Rendered to:**VPI QUALITY WINDOWS
Spokane, Washington**PRODUCT TYPE:**PVC Composite Window Assembly
incorporating a Horizontal Sliding Window (XOX) over Fixed/Fixed/Fixed
SERIES/MODEL: Endurance**SPECIFICATIONS:**AAMA/WDMA/CSA 101/I.S.2/A440-11, NAFS 2011 - *North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, NAFS - *North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, NAFS - *North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

| Title | Summary of Results |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11 | Class LC PG50 2745 x 2438 (108 x 96) Type HS |
| Design Pressure | ±2400 Pa (50.13 psf) |
| Air Infiltration | 0.26 L/s/m ² (0.05 cfm/ft ²) |
| Air Exfiltration | 0.22 L/s/m ² (0.04 cfm/ft ²) |
| Canadian Air Infiltration/Exfiltration Level | A3 |
| Water Penetration Resistance Test Pressure | 360 Pa (7.52 psf) |

Test Completion Date: 03/29/17

Reference must be made to Report No. G9229.01-901-44, dated 04/27/17 for complete test specimen description and detailed test results.