



TEST REPORT

Report No.: F4834.01-901-44

Rendered to:

VPI QUALITY WINDOWS
Spokane, Washington

PRODUCT TYPE:

PVC Composite Window Assembly,
incorporating a Horizontal Sliding Window (XO) over Fixed/Fixed

SERIES/MODEL: Endurance

SPECIFICATIONS:

AAMA/WDMA/CSA 101/I.S.2/A440-11, *NAFS 2011 - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

AAMA/WDMA/CSA 101/I.S.2/A440-08, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

and

CSA A440S1-09, Canadian Supplement to AAMA/WDMA/CSA 101/I.S.2/A440, *NAFS - North American Fenestration Standard/Specification for Windows, Doors, and Skylights*

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 and -11	Class LC PG25 1982 x 2536 (78 x 100) Type HS
Design Pressure	±1200 Pa (25.06 psf)
Air Infiltration	0.13 L/s/m ² (0.03 cfm/ft ²)
Air Exfiltration	0.14 L/s/m ² (0.03 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	440 Pa (9.20 psf)

Test Completion Date: 01/26/16

Reference must be made to Report No. F4834.01-901-44, dated 02/19/16 for complete test specimen description and detailed test results.